

TOWN OF TEMPLETON, MASSACHUSETTS
160 Patriots Rd., Rm. 6
East Templeton, MA 01438
Invitation for Bids
Police Station – HVAC System

ADDENDUM #1 – September 7, 2022

All bidders are required to acknowledge addenda in the appropriate section of the bid documents. Failure to do so may result in rejection of the bid.

1.) THE SUBMISSION DUE DATE HAS CHANGED: Final bids must be received by 2:00 pm on Wednesday, September 28, 2022.

2.) CLARIFICATION / ADDITIONAL REQUIREMENTS HIGHLIGHTED:

Drawings/Specifications: The attention of bidders submitting bids for the above subject project is called to the following addendum to the specifications and drawings. The items set forth herein, whether of omission, addition, substitution, or clarifications are all to be included in and form a part of the bid submitted.

Pre-Bid Conference: A Pre-Bid Conference has been scheduled for Wednesday September 21, 2022, at 10 am.

Final Questions: Final questions must be received, in writing by mail (address in bid packet), by email (alamontagne@templetonma.gov), by Adam Lamontagne, Town Administrator, no later than 4:00 p.m. on Monday, September 19, 2022.

Final Addendum: Any/Final addendum will be posted on the Town web site no later than 4:00 p.m., on Wednesday, September 21, 2022.

3.) QUESTIONS:

Q. What is the current BMS/ATC system in the building that the new equipment will be tied into?

A. The existing ATC system is a Johnson Controls System. However, there is no building management system (BMS). Addendum #2 is going to include adding a new BMS.

- End -