

**TOWN OF TEMPLETON, MASSACHUSETTS  
160 Patriots Rd., Rm. 6  
East Templeton, MA 01438**

**Invitation for Bids**

**Electrical Work for Scout Hall & Visitor's Center**

**ADDENDUM #1 – February 28, 2024**

**Please be Sure to Acknowledge This on Your Submission**

**1.) THE SUBMISSION DUE DATE *HAS NOT* CHANGED**

**2.) CLARIFICATION / ADDITIONAL REQUIREMENTS HIGHLIGHTED: None**

**3.) QUESTIONS:**

Q. Spacing and placement of Electrical receptacles and whether I am able to use existing outlets towards the total count of 8 wall receptacles.

A. Yes, using existing outlets to be included.

Q. Placement of 4 Keyless lights in the basement.

A. Yes, the selected bidder must plan on supplying and installing lights in the basement.

Q. Placement of the exterior emergency light and its addition to the exterior light above the side door controlled by a single pole switch.

A. Yes, in addition to outside light.

Q. Additional requirement made by the wiring inspector.

A. The requirements of the wiring inspector would need to be discussed with them prior to commencement of work.

- End -